



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to: **H.B. FULLER CONSTRUCTION ADHESIVES OF
DALTON, GA** 1702 KIMBERLY PARK DRIVE; ZIP CODE: 30721

Category: Construction Materials - Paints & Coatings
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 ID+C, BD+C *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
CHPS 2019 Core Criteria 3.0 EQ C6.1.5 *paints & coatings*

Certified Products: Moisture Vapor Barriers: *TEC® LiquiDam™**, Chapco® Defender™, TEC® LiquiDam EZ.*
** Product tested as representative exemplar of products listed above.

Test Date: July 11, 2023 Report No.: 2300435 Certificate No.: MAS2300435-01

Valid: July 2023 to July 2024



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope