

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

H.B. Fuller Construction Products/ Royal Adhesives and Sealants

1702 Kimberly Park Dr., Dalton, GA, United States

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Standard Product Application Amount: 810 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-07321

Valid from: November 1, 2023 to September 30, 2024



ANSI National Accreditation Board
ACCREDITED
ISO/IEC 17065
PRODUCT CERTIFICATION
BODY

A handwritten signature in black ink that reads 'Stanley Mathuram'.

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

Certification Addendum

H.B. Fuller Construction Products/ Royal Adhesives and Sealants

Certification: Registration # SCS-FS-07321 | Valid from: November 1, 2023 to September 30, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

Addendum **FloorScore®**

Conformance: Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Standard Product Application Amount: 810 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard

Products: **Specialty Construction Adhesives:**

AIM 382, Flexera 2K PSA Hybrid Adhesive, Fusion Series 4500, Fusion Series 4700, TEC 1500, Millennium Series 2009, Probond Premium Acrylic Wood Adhesive, MVR-8000, TEC 726, Wood Go, Wood Ready, Wood Secure